


Model: 1227/500, 1332/500 & 1437/500 (NP) Negative Pressure Specifications

The Vent-A-Kiln model 1227/500, 1332/500 & 1437/500 (NP) negative pressure ventilation system shall include a conical metal spun aluminum hood tapering to a 6.0" diameter exit. A single speed motor with fan (blower) mounted to wall by means of a support bracket, shall draw and propel exhaust fumes and heat via a flexible hose to a exterior surface mounted gravity operated louver. The placement of the hood and blower subassembly shall be user adjustable via an overhead pulley and counterweight system.

- 1) Conical collection hood:
- Metal spun from 0063 gage aluminum, alloy 1100-0.
- 2) Non-explosion proof blower
- $\frac{1}{8}$ hp, 1760/115 motor.
- 450 cfm @ 0.0' w.g., 36 amps, 1600 rpm, 250 deg. f.
- Maximum continuous motor Temperature 250 deg. f.
- Sound data: approximate db at 5 feet: high 68db, low 54db.
- 3) Flexible exhaust hose:
- Triple ply laminate, aluminized polyester face and an aluminum foil backing.
- Corrosion, moisture, temperature (250 deg. f.), and flame resistant.
- 6.0" diameter, 10' (ft.) length.
- Flexible hose fastened by plastic hose clamps (qty=2).
- UL listed number 723.
- Cut to shortest length permissible.
- 4) Exterior surface mounted louver:
- 6.0" diameter discharge.
- Bird screen.
- 5) $\frac{3}{8}$ " diameter plastic coated steel cable
- 10' (ft.) length.
- Two (2) $\frac{3}{8}$ " galvanized steel cable clamps
for fastening cable to counterweight and blower.
- 6) Counterweight:
- 3.0" diameter cold rolled steel, painted VAF/VAK black.
- 7) Overhead pulley system:
- 1.0" x 1.0" x 24.0" length structural tubing.
- two (2) ball bearing pulleys and one (1) resistance pulley.
- Two (2) slide brackets for hanging of system.
- two (2) pulley safety straps.

Model	Hood Diameter A (in)	C.W. (lbs)	D.A.W. (lbs)
1227/500-NP	27.0	6.0	51.0
1332/500-NP	32.0	7.0	54.0
1437/500-NP	37.0	11.0	61.0

C.W. - Counter Weight (6)
D.A.W. - Overall Weight (6)



Vent-A-Fume			
Vent-A-Kiln Corp.			
PROJECT XXX			
NUMBER BY B. Brandon			
DATE 4/10/07			
CHECKED BY _____			
SCALE N/T			
BILL OF MATER			
ALL INFORMATION CONTAINED HEREIN			
IS PROPRIETARY AND MUST NOT BE			
REPRODUCED OR MADE PUBLIC WITH-			
OUT WRITTEN CONSENT FROM			
Vent-A-Fume/Vent-A-Kiln Corp.			
LETTER	ALTERATION	DATE	BY