

4) Exterior surface mounted louver:6.0" diameter discharge.Bird screen. - Triple ply laminate, aluminized polyester face and an aluminum foil backing.
- Corrosion, moisture, temperature (250 deg. f.), and flame resistant.
- 6.0" diameter, 10" (ft.) length.
- Flexible hase fastened by plastic hose clamps (qty=2). $\vec{\mathbf{g}}'$ diameter plastic coated steel cable: - 15' (ft.) length. Three (3) gravity operated shutters. Cut to shortest length permissible UL listed number As per Mai ufacture SE SE Hood o (b)

6) Counterweight:3.0" diameter cold rolled steel, painted VAF/VAK black.

Two (2) 13' galvanized steel cable clamps for fastening cable to counterweight and blower

0

(Reference only). Electric Klin

Top Loading

0 0 ე

weight 36.0 lbs..

7) Swing wall bracket with pulley system:
 Continuos friction hinge design.
 1.0"x1.0"x45.0" length structural tubing.

(See DEM (manual) for installation)

Five (5) ball bearing pulleys. Five (5) pulley safety straps. Wall to center of hood when

8) Over all weight: approximately 78lb.

hood when SWB is perpendicular is 46.5" New Continuos Friction S.W.B. Design Added Blower motor had two **ALTERATION** 4/4/07 B.Brandon 6/12/09 DATE B.Brandon В ALL INFORMATION CONTAINED HEREIN
IS PROPRIETIARY, AND MUST NOT BE
REPRODUCED OR MADE PUBLIC WITHOUT WRITTEN CONSENT FROM
Vent-A-Fume/Vent-A-Klin Corp. 1.) .XXX
2.) .XX
3.) FRACTIONAL DIMENSIONS
4.) ANGLES UNLESS SHOWN OTHERWISE TOLERANCES SHOULD BE: ± .005 ± .01 ± 1/32° ± 0° 30° TILE Model: 1654 With Swing Wall DNG. NO.

Reacket (P-10 Blower) B-1059Vent-A-Kiln Corp. Buffalo, N.Y. 14216 Vent-A-Fume Bracket 51 Botsford Place Positive Pressure (P-10)SCALE DATE 8/28/03 PROJECT NUMBER N7S ⋛ All Dimensions Inches CHECKED BY BRAWN B. Brandon BILL OF MAT'L ωŘ